CCN 47704264001 Rev D ECN 1479846



COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

				MODEL I									
1	Manufacturer: Ingersoll Rand												
	Model 1	Numbe	er E	315n-A155	(NA-IP	23)			Date	: 1	February 2023		
2	X Air-cooled Water-cooled								Type:		Screw		
	Oil Injected X Oil-Free								# of Stages:		2		
3*	Full Lo	ad Ope	erating Press	sure ^b	150			psig ^b					
4	Drive Motor Nominal Rating								122		hp		
5	Drive Motor Nominal Efficiency								5.5%		percent		
6	Fan Motor Nominal Rating (if applicable)								5.0		hp		
7	Fan Motor Nominal Efficiency								92.1%		percent		
8*	Input Power (kW)								Capacity (acfm) a,d		Specific Power kW/100 acfm) ^d		
	348.9 Max								1570		22.23		
	297.5								1372		21.68		
	250.2							1166			21.45		
	206.4							954			21.64		
	165.7								735		22.54		
	127.4 Min							510			24.96		
9*	Total Package Input Power at Zero Flow ^{c, d}							0.0			kW		
		35.00											
		30.00											
	Specific Power (kW/100ACFM)	25.00											
10		20.00											
		15.00											
		10.00	0 200	400	600	800 Capac	1000 ity (ACFI	1200 M)	1400	1600	1800		
	Note: Graph is only a visual representation of the data in section 8 Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity												

^{*} For models that are tested in the CAGI Performance verification Program, these items are verified by program administrator and the CAGI Performance verification of the program administrator and the program administration and the program administration and the program administration and the program administration are program and the program administration and t

Consult CAGI website for a list of participants in the third party verification program:

www.cagi.org

- NOTES:

 a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;

 ACFM is actual cubic feet per minute at inlet conditions.
 - $b. \ \ The operating \ pressure \ at \ which \ the \ Capacity \ and \ Electrical \ Consumption \ were \ measured \ for \ this \ data \ sheet.$
 - C. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1% manufacturer may state "not significant" or "0" on the test report.
 - d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document

110 123 The terms power and energy are symonymous for purposes of this document											
Volume : at specified	flow rate I conditions	Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power							
m ³ /min	ft ³ /min	%	%								
Below 0.5	Below 17.6	+/-7	+/-8								
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%							
1.5 to 15	53 to 529.7	+/-5	+/-6								
Above 15	Above 529.7	+/-4	+/-5								

Member

ROT 031.2

12/19 R3

This form was developed by the Compressed Air and Gas Institute for the use of its members. CAGI has not independently verified the reported data