47573563 Rev E ECN 1418415



COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Variable Frequency Drive

		FOR COMPRESSED AI					
1	Manufacturer: Ingersoll Rand						
	Model Number RS30n-A145		Date:	12/23/20	20		
2	X Air-cooled Water-cooled	Туре:	Type: Screw				
			# of Stages:	1			
3*	Full Load Operating Pressure ^b	135		psig ^b			
4	Drive Motor Nominal Rating	40		hp			
5	Drive Motor Nominal Efficiency	92.4		percent			
6	Fan Motor Nominal Rating (if applicable) 1.1		hp			
7	Fan Motor Nominal Efficiency	87.5		percent			
	Input Power (kW)	Capacity (acfm) a,d		Specific Power (kW/100 acfm) ^d			
	37.6	171.0	2	22.01			
	33.5	147.2	2	22.73			
8*	29.7	128.3	2	23.17			
	26.1	109.8	23.75				
	22.6	91.2	24.74				
	19.7	74.2	2	26.51			
9*	Total Package Input Power at Zero Flow ^c ,	0		kW			
10	Isentropic Efficiency	62.4		percent			
11	29 27 25 25 28 29 29 20 20 30 30 30 30 30 30 30 30 30 30 30 30 30		120 140) 160	180		
	Capacity (ACFM) Note: Graph is only a visual representation of the data in section 8 Note: Y-axis scale 10 to 35, -SkW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum canacity						

X-Axis Scale, 0 to 25% over maximum capacity
*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator
Consult CAGI website for a list of participants in the hird party exprising the program.

Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES: a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.



- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume flow rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power	
m³/min	ft ³ /min	%	%	%	
Below 0.5	Below 17.6	+/-7	+/-8		
0.5 to 1.5	17.6 to 53	+/-6	+/-7	+/- 10%	
1.5 to 15	53 to 529.7	+/-5	+/-6		
Above 15	Above 529.7	+/-4	+/-5		

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.